

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7080-0067:038 Page 1 of 1

CATEGORY: Halogenated Extinguishing Systems

LISTEE: Siemens Building Technologies Inc., *Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932
Contact: Peter Pawchak (973) 593-2662 FAX (973) 593-6652

DESIGN: Models H125, H250, HL250, H350, HL350, H600 and HL600. Total flooding Halon 1301. Rebuilt models are designated by an "R" in the model number and are otherwise as described herein. Cylinders may be discharged manually, electrically or pneumatically. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Cerberus Pyrotronics, model number and FM or UL label.

APPROVAL: Listed as halogenated extinguishing system. Electrical release requires manufacturer's HC-35 or RM-30U/-30RU or HC-35 release module, which must be integrated with listed System 3 control unit (CSFM Listing No. 7165-0067:035) or CP-2H, CP-2HA or CP-2HR control unit (CSFM Listing No. 7165-0067:120) for releasing service or SPX-1 control unit (CSFM Listing No. 7165-0067:120) which must be integrated with the Model XL3 (CSFM Listing No. 7165-0067:104) control unit. May be used with Models MH51, MH57, MH501 or MH51X pull stations (CSFM Listing No. 7150-0067:036).

*Rev. 10-26-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 18, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager